

STATEMENT OF CONFORMITY TO STANDARDS
No. 89668SOCSTD

ATTESTATO DI CONFORMITA' ALLE NORME
N°89668SOCSTD

<p>Equipment <i>Apparato</i></p>	<p>Anti-panic break-out system for powered pedestrian door leaf and side screen model 930SNF – 930SNFA – 940SM – 940SMA – A100-Compact - A140 AIR <i>Sistema antipánico a sfondamento per ante mobili e semifisse per porte pedonali automatiche modello 930SNF – 930SNFA – 940SM – 940SMA – A100-Compact - A140 AIR</i></p>
<p>Applicant <i>Richiedente</i></p>	<p>FAAC SpA Via Calari, 10 – 40069 ZOLA PREDOSA ITALY</p>
<p>Manufacturer <i>Costruttore</i></p>	<p>FAAC SpA Via Calari, 10 – 40069 ZOLA PREDOSA ITALY</p>
<p>Model/type <i>Modello / Tipo</i></p>	<p>APN</p>
<p>Ratings <i>Dati tecnici</i></p>	<p>--</p>
<p>Additional information <i>Informazioni aggiuntive</i></p>	<p>--</p>
<p>Variants <i>Varianti</i></p>	<p>APN1 – 1 leaf APN2 – 2 leaves APN1+1 – 1 leaf and 1 side screen APN2+2 – 2 leaves and 2 side screens</p>
<p>The tested equipment was found complying the requirements of the standard(s) <i>L'apparato provato è risultato conforme alla(e) norma(e)</i></p>	<p>DIN 18650-1:2005 Sub-clause 5.8.3.3 Powered doors with break-out (Additional requirements for doors in escape routes and emergency exits) DM 10-3-1998 n°64 Allegato III – Misure relative alle vie di uscita in caso di incendio – Punto 3.11 – Porte scorrevoli e porte girevoli</p>
<p>Results of performed tests are shown in the test report(s) <i>I risultati delle prove eseguite sono riportati nel(i) rapporto(i) di prova</i></p>	<p>Nemko Spa 89668TRFSAF issued 2007-07-20</p>

This Statement of Conformity to Standards refers to the tested sample(s), does not involve production surveillance and does not allow the use of the Nemko mark on the product.
Questo Attestato di Conformità alle Norme si riferisce al campione(i) provato(i), non include la sorveglianza della produzione e non permette l'apposizione del marchio Nemko sul prodotto.

Date of issue: **2007-07-20**
Data di emissione

Nemko S.p.A.
Certification Dpt.

.....
Alberto Reati

This document is composed by 1 page
Questo documento è composto da 1 pagina